

Registered & Head Office :
TUV INDIA PRIVATE LIMITED
827, 2nd floor, Dhun Building
Anna Salai,
Chennai 600 002, India
CIN : U74140MH1989PTC052930
Phone : (044) 28528875 / 1052
Toll Free : 1800-209-0902
Fax : (044) 28521676
Email : chennai@tuv-nord.com
Website : www.tuv-nord.com/in

Date: 4th March 2021

Certification

This is to certify that the **Tamil Nadu Physical Education & Sports University** has successfully completed **Energy, Environment and Green Audit** as per **NAAC criterion 7** located at Melakottaiyur, Chennai.

Audit Month: February 2021

Period of study: 2019-20 & 2020-21

N. Pradeep Kumar



N Pradeep Kumar

Associate Vice President – Certification, Tamil Nadu Region

GREEN AUDIT REPORT
For
TAMIL NADU PHYSICAL EDUCATION AND
SPORTS UNIVERSITY
Melakottaiyur, Chennai.



By



TÜV INDIA PRIVATE LIMITED,
TÜV NORD GROUP
2nd floor, Dhun Building, 827,
Anna Salai, Mount Road, Chennai – 600 002

March 2021



ACKNOWLEDGEMENT

TUV India Pvt Ltd wishes to thank all the staff and Management of **Tamil Nadu Physical Education and Sports University (TNPESU)**, Chennai Management & Technical Team for the kind cooperation and assistance extended to our Auditors during the course of the Green audit.

Auditors

S Prabhu Kiran

Prakash G



Table of Contents

1. EXECUTIVE SUMMARY.....	5
2. LIST OF PERFORMANCE IMPROVEMENT MEASURES AT TAMIL NADU PHYSICAL EDUCATION AND SPORT UNIVERSITY, CHENNAI.	6
3. PROJECT BACKGROUND.....	7
4. GREEN AUDIT	8
5. ELECTRICAL SYSTEM.....	9
5.1 ELECTRICAL BILL ANALYSIS.....	10
5.2 UNIT COST ANALYSIS	12
5.3 LIGHTING ANALYSIS.....	14
5.4 LIGHTING ANALYSIS.....	14
5.5 LIGHTING POWER DENSITY	15
6. HEATING VENTILATING & AIR CONDITIONING (HVAC)	16
6.1 PERFORMANCE ANALYSIS OF SPLIT UNITS.....	16
6.2 INDOOR AIR QUALITY.....	19
7. WATER.....	20
7.1 PERFORMANCE ANALYSIS OF WATER FAUCETS	20
7.2 PERFORMANCE ANALYSIS OF DOMESTIC WATER PUMPS	21
7.3 WATER NEUTRALITY	22



7.4	WATER QUALITY ANALYSIS	24
7.5	WATER BALANCE CHART.....	25
7.6	RAINWATER HARVESTING SYSTEM	25
8	WASTE MANAGEMENT SYSTEM	26
9	GREEN HOUSE GAS EMISSION	28
10	SITE OBSERVATION REPORT	29
11	PERFORMANCE IMPROVEMENT MEASURES (PIM'S)	38
12	GOOD PRACTICES AT TNPSU CAMPUS	44



1. EXECUTIVE SUMMARY

Green Audit of Tamil Nadu Physical Education and Sports University was carried out by TUV India Pvt Ltd team during Feb 2021.

The approach taken in this facility included different tools such as preparation of questionnaire, physical inspection of the campus, observation and review of the documentation, interviewing key persons and associated systems & equipment, including the electrical, lighting & AC systems, and operational & maintenance procedures. Sample measurements were taken using various instruments like ALM Power Analyzer, clamp meter, Infrared Thermometer, Lux meter, Humidity meter, CO₂ meter, etc. Operational Data were also collected from the past records. The study covered the following areas to summarize the present status of environment management in the campus:

- Water management
- Energy Conservation
- Waste management
- Green area management

The report accounts for the energy consumption patterns of the Tamil Nadu Physical Education and Sports University based on actual assessment. The report compiles a list of possible actions to conserve and efficiently access the available scarce resources and their saving potential was also identified.

The overall annual energy consumption is 21,82,442 kWh/annum. The annual greenhouse gas emissions equivalent for electricity is **1855 tons of CO₂** (0.85kg of CO₂ emits /kWh of unit generation).

Total Global Warming Impact in CO₂ Equivalent

S.No	GHG source	Tonnes of CO ₂ Equivalent
1	Road Transport	1.77
2	Electricity	1855
3	HVAC System	1.2
4	DG Operation	2.24
Total GHG Emission		1860.21



Overall 31% i.e. **6,77,081.6 kWh** unit's savings identified on above mentioned categories with average payback of **53 months** and reduced annual greenhouse gas emissions equivalent to **575.5 tons of CO₂**.

2. LIST OF PERFORMANCE IMPROVEMENT MEASURES AT TAMIL NADU PHYSICAL EDUCATION AND SPORT UNIVERSITY, CHENNAI.

S No	ECM Description	Annual Energy savings kWh	Annual savings, Lacs.	Cost of Measure, Lac.	Payback Months
1	PIM 1: Water saving through the efficient dual flush water closet	1281.6 L/Annum	0.11	0.05	6
2	PIM 2: Tube light lamps to be changed with appropriate LED lamps to reduce power consumption	2520	0.25	0.5	24
3	PIM 3: Replacing old ceiling fan to Super fans	16,128	1.64	4.8	35
4	PIM 4: Install Solar PV in roof top to reduce overall power consumption	6,57,100	67	300	53
Total		6,77,081.6	69	305.35	53



3. PROJECT BACKGROUND

The Tamil Nadu Physical Education and Sports University (TNPESU) is India's first state university for Physical Education and Sports located at Melakottaiyur, Chennai. It was established by an Act of the Government of Tamil Nadu in 2004. The University is UGC approved and offers regular and distance learning UG, PG, Diploma, Certificate and PG Diploma programmes in the fields of Physical Education, Yoga, Exercise Physiology, Bio-Mechanics, Sports Management, Sports Psychology and Sociology, Advanced Sports Training and Sports Technology. Tamil Nadu Physical Education and Sports University has a "B++" grade accreditation by the National Assessment and Accreditation Council [NAAC]. Tamil Nadu Physical Education and Sports University has an area of 125 acres which is spread in the outer of Chennai city.

Tamil Nadu Physical Education and Sport University major facilities: -

- Indoor & Outdoor stadium
- Health Centre
- Food Court
- Recreational Center
- Sports Pavilion and Gymnasium



4. GREEN AUDIT

The main objective of the green audit is to promote the Environment Management and Conservation in the College Campus. The purpose of the audit is to identify, quantify, describe and prioritize framework of Environment Sustainability in compliance with the applicable regulations, policies and standards.

The main objectives of carrying out Green Audit are:

- To introduce and aware students to real concerns of environment and its sustainability
- To secure the environment and cut down the threats posed to human health by analyzing the pattern and extent of resource use on the campus.
- To establish a baseline data to assess future sustainability by avoiding the interruptions in environment that are more difficult to handle and their corrections requires high cost.


Green Audit also includes the preliminary analysis and more detailed energy calculations- financial analysis of proposed Performance Improvement Measures (PIM). The financial analysis provides the facility team the understanding of the financial benefits in implementing specific Performance Improvement Measures. Utility bills were collected for three months' period to allow the auditor to evaluate the facility's energy/demand rate structures and energy usage profiles. A detailed financial analysis is performed for each measure based on implementation cost estimates; site-specific operating cost savings, and the customer's investment criteria. Sufficient detail is provided to justify project implementation.



5. ELECTRICAL SYSTEM

The electrical power is availed from Telangana Southern Power Distribution Company Limited (TSSPDCL). The power is distributed through LT panel located in the Facility Area. The power is distributed to the college through transformer of loading position 11KV/433V, 315kVA distribution transformer.

There is 1 No. of 45 kVA & 1 Nos. of 160 kVA DG set for the backup to handle any grid power interruption.





5.1 ELECTRICAL BILL ANALYSIS

The Energy bill data were analyzed from Jan 2020 to Dec 2020, the total electricity bill for the year 2020 is Rs.21,82,442 and energy unit consumption is 2,19,190 kWh.

Month	Energy Consumption kWh	Energy Cost Rs	Unit Cost Rs/kWh
Jan-20	29,630	2,54,219	8.58
Feb-20	23,147	2,13,051	9.20
Mar-20	21,979	2,05,635	9.36
Apr-20	11,098	1,36,540	12.30
May-20	14,638	1,59,019	10.86
Jun-20	14,800	1,60,048	10.81
Jul-20	13,937	1,54,568	11.09
Aug-20	16,138	1,68,544	10.44
Sep-20	18,948	1,84,108	9.72
Oct-20	18,974	1,86,603	9.83
Nov-20	15,920	1,67,160	10.50
Dec-20	19,981	1,92,947	9.66
Total	219,190	21,82,442	10.20

Table: Energy Bill Analysis Jan'20 to Dec'20




Chart: kWh Consumption analysis – During Jan 2020 energy consumption is high






Chart: Monthly Energy Cost Analysis – During Jan 2020 energy cost is high

5.2 UNIT COST ANALYSIS

The Energy bill data from Jan 2020 to Dec 2020 were analyzed. Per unit cost for the period of study was calculated to be Rs 10.20/kWh.

Month	Energy Consumption kWh	Energy Cost Rs	Unit Cost Rs/kWh
Jan-20	29,630	2,54,219	8.58
Feb-20	23,147	2,13,051	9.20
Mar-20	21,979	2,05,635	9.36
Apr-20	11,098	1,36,540	12.30
May-20	14,638	1,59,019	10.86
Jun-20	14,800	1,60,048	10.81
Jul-20	13,937	1,54,568	11.09
Aug-20	16,138	1,68,544	10.44
Sep-20	18,948	1,84,108	9.72
Oct-20	18,974	1,86,603	9.83
Nov-20	15,920	1,67,160	10.50
Dec-20	19,981	1,92,947	9.66
Total	219,190	21,82,442	10.20




Chart: Monthly Unit Cost – During Apr 2020 Unit Cost Rate is high.



5.3 LIGHTING ANALYSIS

Good lighting is necessary to enable work to be done well and in comfort. A facility with bad lighting is an inefficient one, though it may look attractive. Poor lighting can be combated by good eyesight and by keenness on work but at the eventual expenses of efficiency, wellbeing and comfort. Hence, the designer of the building should pay sufficient attention to the need for good lighting.

The lighting details of the facility were studied. The various type of light fitting used are 15W LED, 20W LED, 30W LED & 36W TL lamps.

5.4 LIGHTING ANALYSIS

S. No	Description	LUX Level	Baseline Lux Level as per NBC	Remarks
1	Principal Room	170, 195, 210, 280,324	300	Ok
2	Library Hall	200, 260, 230, 162,290,332	300	Ok
3	Auditorium	117, 135, 180, 190, 210, 340	300	Ok
4	Server Room	120, 140, 280,320	200	Ok
5	Gents Mess Hall	210,280,320,440	200	Ok
6	Ladies Mess Hall	230,260,310,460	200	Ok
7	Gents Hostel Room	210,280,260,320	50	Ok
8	Ladies Hostel Room	265, 285, 330	50	Ok
11	Lecture Hall 1	250,320,380	300	Ok
12	Lecture Hall 2	230,260,340	300	Ok
13	Lecture Hall 3	220,250,330	300	Ok
14	Lecture Hall 4	250,275,315	300	Ok
15	Lecture Hall 5	235,285,350	300	Ok
16	Lecture Hall 6	270,290,340	300	Ok

Comments:

Lux level is measured during day light availability and it is very good level compared to NBC standards.



5.5 LIGHTING POWER DENSITY

S No	Description	Fixture Details	Fixture Wattage	No. of fixtures	Total Wattage	Area Sq.ft	Actual LPD W/sq.ft	ASHRAE LPD W/sq.ft
1	Gents Mess Hall	36 W TL	36	15	540	2064	0.26	1.21
2	Ladies Mess Hall	36 W TL	36	15	540	1160	0.47	1.21
3	Library Reading Hall	36 W TL	36	48	1728	2760	0.63	0.93
4	Ladies Hostel room 1	36 W TL	36	15	540	1456	0.37	1.21
5	Ladies Hostel room 2	36 W TL	36	15	540	1456	0.37	1.21
6	Ladies Hostel room 3	36 W TL	36	15	540	1456	0.37	1.21
7	Gents Hostel Room 1	36 W TL	36	15	540	1456	0.37	1.21
8	Gents Hostel Room 2	36 W TL	36	15	540	1456	0.37	1.21
9	Gents Hostel Room 3	36 W TL	36	15	540	1456	0.37	1.21
10	Class Room G15	20 W LED	20	12	240	520	0.46	1.24
11	Class Room G16	20 W LED	20	12	240	520	0.46	1.24
12	Class Room G17	20 W LED	20	12	240	520	0.46	1.24
13	Class Room G18	20 W LED	20	12	240	520	0.46	1.24
14	Academic Block Lobby 1	36 W TL	36	4	144	220	0.65	0.9
15	Academic Block Lobby 2	36 W TL	36	4	144	220	0.65	0.9
16	Admin Block Lobby	36 W TL	36	2	72	140	0.51	0.9

Comments:

LPD is within in the ASHRAE limit. We recommended to replace the 36 W TL to 20 W LED for better energy savings.



6. HEATING VENTILATING & AIR CONDITIONING (HVAC)

In College campus for human thermal comfort, sum of 152 TR capacities of split units installed, in Library computer lab, Admin Block and Academic Block are installed in the campus to meet the cooling requirement. Along with this, for ventilation in the facility, ceiling and exhaust fans are installed.

6.1 PERFORMANCE ANALYSIS OF SPLIT UNITS

Admin Block Server Room AC 1		
Description	Name Plate Details	
Make	Voltas	
Motor Power, kW	1.77	
Rated Current, A	7.9	
Refrigerant & Charge	R-22, 1.13 kg	
Capacity, TR	2	
Star Rated	5 Star	
Inside Air Flow, CMH	1080	
Performance Analysis		
Description	Actual	Units
Motor running current	5.8	A
Voltage	227.2	V
PF	0.91	
Motor power	1.51	kW
Supply air quantity	110	CFM
Supply air temperature	19.3	°C
Relative humidity	62	%
Return air temperature	21.8	°C
CO ₂ Level	765	PPM

Comments:

Power consumption is within the design limit and CO₂ level is within limits.



Admin Block Server Room AC 2		
Description	Name Plate Details	
Make	Voltas	
Motor Power, kW	1.77	
Rated Current, A	7.9	
Refrigerant & Charge	R-22, 1.13 kg	
Capacity, TR	2	
Star Rated	5 Star	
Inside Air Flow, CMH	1080	
Performance Analysis		
Description	Actual	Units
Motor running current	5.6	A
Voltage	221.9	V
PF	0.9	
Motor power	1.48	kW
Supply air quantity	105	CFM
Supply air temperature	21.1	°C
Relative humidity	61	%
Return air temperature	22.7	°C
CO ₂ Level	756	PPM

Comments:

Power consumption is within the design limit and CO₂ level is within limits.



Academic Block Health Care Room AC 1		
Description	Name Plate Details	
Make	LLOYD	
Motor Power, kW	1.59	
Rated Current, A	7.0	
Refrigerant & Charge	R-22, 1.08 kg	
Capacity, TR	1.5	
Star Rated	3 Star	
Performance Analysis		
Description	Actual	Units
Motor running current	6.7	A
Voltage	223.7	V
PF	0.9	
Motor power	1.5	kW
Supply air quantity	96	CFM
Supply air temperature	21.5	°C
Relative humidity	65	%
Return air temperature	22.9	°C
CO ₂ Level	670	PPM

Comments:

Power consumption is within the design limit and CO₂ level is within limits.



6.2 INDOOR AIR QUALITY

Indoor air quality (IAQ) is a term which refers to the air quality within and around buildings and structures, especially as it relates to the health and comfort of building occupants. IAQ can be affected by various gases, volatile organic compounds etc. Source control, filtration and the use of ventilation to dilute contaminants are the primary methods for improving indoor air quality in most buildings. Determination of IAQ involves the collection of air samples at various locations of the building.

During the course of audit, the Indoor air quality survey was carried out at various locations in the building.

S.No	Area	Temperature	CO ₂ ppm	Relative Humidity %
1	Auditorium	21.6	640	61
2	Library Computer Lab - 1	23.4	810	60
3	Health Care room	20.8	670	65
4	Admin Block Server room	19.9	765	61

Comments:

On an overall observation, the occupant comfort temperature shall be maintained at 24°C, & Humidity needs to be maintained at < 60%. CO₂ level is good.



7 WATER

Drinking Water for the entire college is taken from quarry and it treated by proper RO system. RO water system are installed in each block to meet the drinking water requirement. For flushing, irrigation and cleaning purpose water is taken from the same quarry, water is pumped to the raw water sump then the OHT at terrace levels.

7.1 PERFORMANCE ANALYSIS OF WATER FAUCETS

Water flow is measured in faucets of College toilets wash basin, urinals & water closets.

S. No.	Description	NBC Baseline (LPM)	Actual (LPM)
1	First floor gents toilet wash basin 1	1.5	7.1
2	First floor gents toilet wash basin 2	1.5	6.8
3	Ground Floor ladies toilet tap 1	3	17.0
4	Ground Floor ladies toilet tap 2	3	18.9
5	Wash basin tap 1	1.5	11.0
6	Wash basin tap 2	1.5	13.0
7	Water Closets	6	6.0
8	Academic Block first floor Wash basin tap 1	1.5	7.5
9	Academic Block first floor water closet 1	6	6.0
10	Academic Block first floor water closet 2	6	6.0
11	Admin Block ground floor Wash basin tap 1	1.5	5.5
12	Admin Block ground floor water closet 1	6	6.0

Comments: Water flow in the faucets and tap are high in above highlighted area comparing to the NBC standard. The baseline standards are as per the NBC 2016 part no: 9 section 1 table – 2.



7.2 PERFORMANCE ANALYSIS OF DOMESTIC WATER PUMPS

Water Pump-1

Description	Bore Well Water Pump -1
Installed motor power, kW	3.75
No. of Phase	3
Description	Readings
Voltage, V	404.8
Current, A	4.8
Power Factor, PF	0.943
Power consumption, kW	3.17

Comments:

Power consumption is within the design limit. Water meter shall be installed in outlet of the quarry motor pipe to measure the water consumption from the quarry and consumption in each block. Quarry water Consumption Record shall be maintained on daily, monthly basis to arrive at the water balancing.

Sump Water Pump-1

Description	Sump Water Pump -1
Make	C R I
Capacity, m ³ /hr	9
Motor current, A	3.0
Motor RPM	2880
Installed motor power, kW	1.1
Head, m	32
Description	Readings
Voltage, V	421
Current, A	2.1
Power Factor, PF	0.787
Power consumption, kW	0.9

Comments:

Power consumption is within the design limit. Water meter shall be installed at the overhead tank outlet to measure the water consumption from the terrace tank. Water Consumption Record shall be maintained on daily, monthly basis to arrive at the Water balancing.



Sump Water Pump -2

Description	Sump Water Pump -1
Make	C R I
Capacity, m ³ /hr	9
Motor current, A	3.0
Motor RPM	2880
Installed motor power, kW	1.1
Head, m	32
Description	Readings
Voltage, V	421
Current, A	2.8
Power Factor, PF	0.823
Power consumption, kW	1.69

Comments:

Power consumption is within the design limit. Water meter shall be installed at the overhead tank outlet to measure the water consumption from the terrace tank. Water Consumption Record shall be maintained on daily, monthly basis to arrive at the Water balancing.

7.3 WATER NEUTRALITY

Presently quarry water is used to meet the entire buildings water requirement.

Strategies for Water Neutrality: -

a. Low flow aerators.

To reduce the fresh water consumption, by installing the aerators for faucets in all common area restrooms, landscape irrigation, canteen etc. This measure reduces the water consumption by 40% from the baseline of NBC.






b. Sewage Treatment Plant

To reduce the potable water consumption by installing the sewage treatment plant (STP). In the college campus 2 hostel blocks are there and totally per day water consumption is 120 KL per day. So the waste water generation will be around 120 KL per day. So the recommended STP plant size will be 120 KLD. This treated water will be used for landscape irrigation & toilet flushing purpose.

c. Dual Plumbing System.

To reduce the potable water consumption by installing the dual flush system (3/6 LPF). To further reduce the fresh water consumption, use the STP treated water as mentioned above.



d. Native Plant Species.

For landscape irrigation, fresh potable water is being used. To reduce water consumption for landscape, in some places drip irrigation method is being used. However, in some places hose pipe irrigation is being used and this result in more water consumption. It is recommended to install drip irrigation for all shrubs & tree type species and sprinkler irrigation for turf area. To reduce the water consumption by replacing the drought tolerant/xeriscape species.



7.4 WATER QUALITY ANALYSIS

In College campus, drinking water is taken from tanker lorry (Costly) and municipal corporation water. Normally, for drinking water daily consumption of lorry water - 8000 liters and municipal water - 250 liters, so totally 8250 liters per day is consumed. For landscape irrigation, floor cleaning & toilet flushing water is taken from two bore well and the total dissolved solid (TDS) level is given below.

Location	Water TDS level	Temperature in ° C
Quarry Water	640	31.4
Ground Floor Water Cooler	260	27.6
Second Floor Water Cooler	253	25.6


Comments:

As per the WHO recommended drinking water TDS level is < 300. In our campus drinking water TDS level is within the limit. For quarry, water treatment system is required to reduce the TDS level.



7.5 WATER BALANCE CHART

Source of drinking water is from the quarry water, to underground reservoir, it is transferred to Overhead tank and supplying the water with the help RO systems. And same quarry water is in usage to meet the landscape irrigation, cleaning & toilet purpose. There is no sewage plant installed in this plant, sewage is connected through the municipal sewerage line.



7.6 RAINWATER HARVESTING SYSTEM

In college campus rainwater is collected and recharge the ground with the help of a quarry water reservoir and Melakottaiyur Lake and the lake and reservoir is located near to the college campus. Rainwater trenches are built according to the slope of the surface level and it connect the roof and non-roof rainwater to rainwater harvesting system.



8 WASTE MANAGEMENT SYSTEM

In college campus, separate dry waste and wet waste type of waste collection bins are provided for collection of waste. All waste generated from the building operation was analyzed. A waste audit was performed on 28/02/2021 at Tamil Nadu Physical Education and Sports University, Chennai to identify opportunities to divert waste streams from landfills and to determine further source reduction opportunities.

Waste Treatment:

Different types of waste are collected from the hostel mess & other places are sent to Municipal. In the college campus is the common solid waste management center for segregation and effective management of waste generated in the college premises. The unit has specific sections where solid waste is segregated as 'wet' and 'dry'. The dry waste such as plastics, papers, cartons, e-waste and scrap are separated and sent to 'recycle vendor' for recycling. The organic waste such as dried leaves and kitchen refuse from the canteen are used for composting.

Month	Cardboard Waste, Kg	Paper Waste, Kg	Plastic Waste, Kg	Bottle Kg	Total Waste, Kg
Mar-19	-	338	-	-	338
Apr-19	-	338	-	-	338
May-19	-	2082	-	-	2082
Jun-19	-	1106	-	-	1106
Sep-19	133	6697	108	16	6954



Oct-19	42	3651	71	20	3784
Nov-19	57	108	29	-	194
Dec-19	131	87	92	30	340
Jan-20	133	19	41	-	193
Feb-20	90	164	99	54	407
Mar-20	27	61	46	-	134
Jan-21	41	7	105	-	153
Feb-21	3802	3070	126	9	7007

Waste Audit Procedure:

- Waste auditing was carried out by sorting and measuring the building's waste over a given time period, i.e. 24 hours' time. And Audit team selected a time period of 16th Feb 2021.
- The Audit Team was equipped with all necessary safety and personal protective devices including safety glasses, respirator masks, coveralls and gloves.
- The Audit team has taken the waste audit form and marked the following types:
 - Papers
 - Tissue paper
 - Pet bottles
 - Plastic covers
 - Printed hard paper
 - Food waste
- Each waste type was separated and measured for the weight through a weighing scale. The values were entered in the waste audit form and compared against the total weight of all wastes.



9 GREEN HOUSE GAS EMISSION

Climate change resulting from human activities is now recognised as one of the most pressing environmental issues facing the world's population. In addressing this problem, governments, the international community and industry are moving to control emissions of greenhouse gases (GHGs), setting targets such as those agreed at the Kyoto Conference in 1997. These moves will continue in the future and, inevitably, businesses and other organizations will increasingly have to account for and report on GHG emissions.


In the college campus total occupants is 847 (approx..) and 367 students are stay in the college hostel and we consider the total travel distance per day is 20 km(approx..) and GHG emission for per kilo meter is 0.000185 tCO₂ / Km. So per day CO₂ emission level is 1.77 tCO₂ for travelling. The total energy unit consumption is 21,82,442 kWh per year and CO₂ emission factor for electricity is 0.85. It is equivalent to 1855 tons of CO₂. For HVAC system installed capacity is 152 TR and charged refrigerant quantity is 60.5 GWP tons and standard refrigerant gas leakage is 2%, It is equivalent to 1.2 tons of CO₂. For Diesel operated 63 KVA DG is installed in site and one-year fuel consumption is 839 liters and CO₂ emission factor for diesel is 0.00268 tCO₂/liter. So one year CO₂ emission from DG is 2.24 tCO₂.

Total Global Warming Impact in CO₂ Equivalent

S No	GHG source	Tonnes of CO ₂ Equivalent
1	Road Transport	1.77
2	Electricity	1855
3	HVAC System	1.2
4	DG Operation	2.24
Total GHG Emission		1860.21



10 SITE OBSERVATION REPORT

Site Observation Report (SOR)			
Report No.	C&A/SOR/01	Date	28.02.2021
Location	College Campus		
Observation Images			
			
Description			
Treated drinking water is provided for the whole campus.			
Potential Sustainability Measures			
Purified drinking water dispenser is kept at each floor level.			



Site Observation Report (SOR)

Report No.	C&A/SOR/02	Date	28.02.2021
Location	Hostel Mess		

Observation Images



Description

In hostel canteen 20 m3 bio gas plant is installed.



Potential Sustainability Measures

It is recommended to use the cattle dung use in the bio gas plant.

Site Observation Report (SOR)

Report No.	C&A/SOR/03	Date	28.02.2021
Location	HVAC System		

Observation Images





Description

High Efficient AC System.

Potential Sustainability Measures

It reduces the power consumption and it is highly efficient.

Site Observation Report (SOR)

Report No.	C&A/SOR/04	Date	28.02.2021
------------	------------	------	------------

Location	Dust Bin
----------	----------

Observation Images





Description

Different type waste collection bins are kept for the collection of waste.

Potential Sustainability Measures

This measure helps in reducing the segregation of waste at source.

Site Observation Report (SOR)

Report No.	C&A/SOR/05	Date	28.02.2021
-------------------	------------	-------------	------------

Location	Hostel Mess
-----------------	-------------

Observation Images



Description




Good ventilation and Day light is available in the hostel mess

Potential Sustainability Measures

In the hostel mess good daylight and ventilation are available, it gives good atmosphere to the students have their food.

Site Observation Report (SOR)

Report No.	C&A/SOR/06	Date	28.02.2021
Location	Academic Block Terrace		
Observation Images			



Description

Cooling tiles are installed in the academic block terrace area

Potential Sustainability Measures

This helps in reducing the HVAC consumptions and maintain the good thermal comfort.

Site Observation Report (SOR)

Report No.


C&A/SOR/07

Date

28.02.2021



Location	Rest Room		
Observation Images			
			
Description			
In rest rooms water urinals are installed.			
Potential Sustainability Measures			
To reduce water consumption, these urinals shall be replaced with Water less urinals.			
Site Observation Report (SOR)			
Report No.	C&A/SOR/08	Date	28.02.2021

Location	Roof Top Solar PV
Observation Images	
	
Description	
Work Order is released for Roof top solar PV.	
Potential Sustainability Measures	
20kVA solar photovoltaic energy plant is going to install in the roof top and it is connecting with net metering.	



11 PERFORMANCE IMPROVEMENT MEASURES (PIM's)

PIM 1: Water saving through the efficient dual flush water closet

Annual Water Savings	1281.6 L/annum
Recurring Annual Savings Potential	Rs. 0.11 Lakhs
One-time Cost of Implementation	Rs.0.05 Lakhs
Payback period	6 Months

Present System:

Presently average water flow in the faucets is 8 LPM it is high compared to the NBC Standards. This leads to lot of water consumption.

Proposed System:

It is recommended to install low flow aerator based faucets in the flow rate of 2.4 LPM as per the standards in common/lavatory rooms. This saves huge of water consumption.

Description	Value	Units	Formula
Average measured flow	8	LPM	A
Average usage per day	60	min/day	B
No of taps	60	Nos.	C
Annual water consumption	8,640	KL/yr	$D = (A \times B \times C \times 300) / 1000$
Water consumption cost (Approx..)	9	Rs/KL	E
Present Water Consumption cost	77,760	Rs/Yr	$F = E \times D$
After installing aerators 70% water reduction	2.4	LPM	G
Annual water Savings	7358.4	KL/yr	$H = ((A - G) \times B \times C \times 365) / 1000$
Annual Saving, Rs	0.11	Lakhs	$I = H \times E$
Investment, Rs	0.05	Lakhs	J
Payback period	6	Months	$K = J / I \times 12$





PIM 2: Tube light lamps to be changed with appropriate LED lamps to reduce power consumption

Annual Energy Savings	2520 kWh/annum
Recurring Annual Savings Potential	Rs. 0.25 Lacs
One-time Cost of Implementation	Rs. 0.5 Lacs
Payback period	24 months

Present System

During the survey, it is observed that some class room and exterior lights are 36W tube lamps are installed with electronic/electromagnetic ballast. These lamps are outdated and power consumption is higher with low lumens output.

Proposed System

It is recommended to replace 15W LED lamps. It gives more lumens and reduces power consumption.

Description	Value	Units	Formula
Total power consumption in Exterior Lighting	1	kW	A
Present Annual Operating Hours	4,200	hrs	B
Present Annual Energy Consumption	4,200	kWh	$C = A \times B$
Proposed Power consumption after installing LED lamps (considering 40% reduction)	0.4	kW	$D = (A - (A \times 40\%))$
Proposed Energy Consumption	1680	kWh	$E = D \times B$
Proposed Energy savings in Units	2520	kWh	$F = C - D$
Power cost	10.2	Rs/kWh	G
Annual Power cost savings	0.25	Rs	$H = F \times G$
One-time cost of implementation	0.5	Rs	I
Payback period	24	Months	$J = I / H \times 12$





PIM 3: Replacing old ceiling fan to Super fans

Annual Energy Savings	16,128 kWh/annum
Recurring Annual Savings Potential	Rs. 1.64 Lakhs
One-time Cost of Implementation	Rs. 4.8 Lakhs
Payback period	35 Months

Present System:

Presently there is old model high energy consumption fans are installed at campus; it is consuming more energy.

Proposed System:

It is recommended to install super fans to reduce the power consumption and armature coil failure.

Description	Value	Units	Formula
Annual Energy Consumption	53760	kWh/yr	A
Proposed Fan Annual Energy Consumption	30	%	B
Annual Energy Savings	16128	kWh/yr	$C = B \times 10\%$
Unit power cost	10.2	Rs/kWh	D
Annual Cost Savings	1.64	Rs Lakhs	E
One time implementation cost	4.8	Rs lakhs	F
Payback	35	Months	$G = F/E \times 12$



PIM 4: Install Solar PV in roof top to reduce overall power consumption

Annual Energy Savings	657, 000 kWh/annum
Recurring Annual Savings Potential	Rs 67 Lakhs
One-time Cost of Implementation	Rs 300.0 Lakhs
Payback period	53 Months

Present System:

Presently TNEB power supply is catering to whole building facility, this leads the power consumption.

Proposed System:

To avoid the TNEB power consumption, this can be avoided by installing Solar PV on Roof Top

Description	Value	Units	Formula
Area of the roof required for PV	40000	Sq.ft	A
Area required for 1 kW PV	100	sq.ft	B
Potential of PV panels	400	kW	C
Average Units generation per kW panel	1,800.0	kWh/day	$E = C \times 4.5 \text{ kWh}$
Annual Energy Generation	657,000	kWh	$F = E \times 365$
Unit power cost	10.2	Rs/kWh	G
Annual Cost Savings	67	Rs Lakhs	H
One time implementation	300	Rs lakhs	I
Payback	53	Months	$J = I / H \times 12$



12 GOOD PRACTICES AT TAMIL NADU PHYSICAL EDUCATION & SPORTS UNIVERSITY CAMPUS

During Conserve's Audit, it is observed that M/s Tamil Nadu Physical Education and Sport University has already adopted the following Performance Improvement Measures in its facility;

12.1 LED Lights in Building facility

LED street light is installed in the college campus is a good replacement of Energy. It reduces the EB energy consumption.

12.2 Solar PV System

Solar PV is installed in the roof top of 20kW is a good replacement of Energy. It reduces the EB energy consumption.

12.3 Bio Gas

Food Waste is converted to bio gas; it is a good example of waste to Energy. It is reducing the hostel mess LPG consumption.

12.4 Green Campus

The college total site is 125 acers and more than 100 acer is complete green vegetation is retained.

12.5 Shuttle Service

College is operating a shuttle service for students and it is connecting Tambaram bus depot to college. It reduces the overall CO2 footprint to a great extent with avoiding individual transport.